


**DEVELOPMENT AND ACREDITATION OF
PROFICIENCY TESTING SCHEMES BASED ON
FLOW AND "IN SITU" PARAMETERS IN
DIFFERENT MATRICES**

Paula Vaquero-Gonzalez, Francisco García-Andreu



Istanbul (Turkey), October 2011




ielab is a company that provides services for the quality control in laboratories such:

- proficiency testing schemes
- certified reference materials

ielab brings together 17 years experience in the organization of Proficiency Testing Schemes together with the 20 years experience of analytical services of LABAQUA.

1. More than 1200 participants from 33 countries
2. Certified according to ISO 9001:2008
3. Accredited by ENAC (Spanish accreditation body) according to ISO 1
4. 24 schemes



- Drinking waters A
- Drinking waters B
- Drinking waters C
- Microbiology in drinking waters
- Directive 2000/60/EC (list of priority substances)
- Raw waters
- DRO+GRO+Hydrocarbons
- Microbiology in continental waters
- Waste waters
- Regenerated waters
- Solids in waste waters
- Microbiology in waste waters
- Sea waters
- Atmospheric pollution
- Organic compounds in solids
- Sludges
- Microbiology in sludges
- Residues
- Soils
- Legionella – culture
- Legionella PCR
- Biota
- PCBs in dielectric oils
- ***In situ* analysis**



Requirements for laboratories and inspection bodies

- Technical capabilities
- Reproducibility of samples
 - * Internal Quality Control (17025 & 17020)
 - * Intercomparations (PTS)



In situ PTS

DEVELOPMENT OF PTS

- Different locations
- Different parameters (flow, pH, T^a , conductivity & dissolved oxygen)
- Different matrices (waste water, sea water & raw water)



DEVELOPMENT OF PTS



Alicante & Cadiz:
three matrices
Madrid: two matrices

1. Previous visit

- Look for the place before (conditions, way of arriving, enough space, ...)
- OK/NOT OK for the PTS
- Primary study of homogeneity and stability

2. Participants

- Minimum of 10 and maximum of 20

3. Instructions

- Place, matrices, equipment, transport to location

4. Previous meeting

- Explain all details according to the test
- Solve doubts of participants

5. Transfer to locations

- Our measurements to check the conditions
- Verify OK/NOT OK
- Measurements from the participants (their own equipments)

- Eurachem-Citac 2007 Guide (measurement uncertainty arising from sampling)
- IUPAC Technical Report (The International Harmonised Protocol for the Proficiency Testing of Analytical Chemistry Laboratories)
- **ILAC-G13:08** "Guidelines for the Requirements for the Competence of Providers of PTS"

HOMOGENEITY AND STABILITY (by IUPAC)

- 10 samples in 2 locations
- Method with a repetibility less than $0.5 \sigma_p$
- Analysis of two replicates in each one of the 10 samples
- Calculus of the variability between samples (S_{am})
- Calculus of the critic value:

$$c = F_1 \sigma_{all}^2 + F_2 S_{an}^2$$

$$\sigma_{all}^2 = (0.3 \sigma_p)^2$$

Homogeneous if $S_{am} < C$

Results of homogeneity and stability (1)

HOMOGENEITY "IN SITU" 2011 (WASTE WATER)							
TIME	PLACE	REPLICATE	pH	CONDUCTIVITY	OXYGEN	TEMPERATURE	FLOW
1	1	1	7.32	2550	1.91	24.64	75.6
2	1	1	7.29	2560	1.82	24.66	76.8
3	1	1	7.29	2560	1.82	24.65	74.1
4	1	1	7.32	2560	1.89	24.64	74.5
5	1	1	7.33	2560	1.90	24.70	76.8
6	1	1	7.32	2550	1.87	24.71	77.6
7	1	1	7.32	2550	1.91	24.70	74.9
8	1	1	7.33	2550	1.92	24.78	72.6
9	1	1	7.31	2540	1.87	24.63	77.2
10	1	1	7.31	2540	1.81	24.60	77.9
1	2	1	7.27	2530	1.85	24.60	73.6
2	2	1	7.35	2540	1.88	24.65	76.1
3	2	1	7.39	2530	1.86	24.66	72.9
4	2	1	7.28	2540	1.95	24.72	73.5
5	2	1	7.36	2540	1.94	24.75	72.1
6	2	1	7.23	2550	1.91	24.61	77.3
7	2	1	7.23	2550	1.82	24.86	73.9
8	2	1	7.30	2530	1.95	24.60	74.6
9	2	1	7.24	2540	1.88	24.71	72.2
10	2	1	7.37	2540	1.87	24.86	75.5
1	1	2	7.31	2540	1.90	24.66	77.9
2	1	2	7.31	2540	1.81	24.65	77.2
3	1	2	7.33	2550	1.82	24.64	72.6
4	1	2	7.32	2550	1.87	24.65	74.9
5	1	2	7.32	2550	1.87	24.70	77.6
6	1	2	7.33	2560	1.88	24.71	76.8
7	1	2	7.32	2560	1.89	24.71	74.5
8	1	2	7.29	2560	1.91	24.66	74.1
9	1	2	7.25	2560	1.85	24.69	76.8
10	1	2	7.32	2560	1.89	24.62	75.6
1	2	2	7.36	2520	1.71	24.70	75.5
2	2	2	7.29	2540	1.85	24.63	72.2
3	2	2	7.24	2540	1.88	24.71	74.6
4	2	2	7.30	2530	1.85	24.69	73.9
5	2	2	7.23	2550	1.79	24.72	77.3
6	2	2	7.23	2550	1.90	24.70	72.1
7	2	2	7.26	2540	1.94	24.69	73.5
8	2	2	7.28	2540	1.85	24.73	73.0
9	2	2	7.39	2540	1.88	24.71	76.2
10	2	2	7.27	2520	1.92	24.62	73.6
MEAN			7.30	2545	1.87	24.68	75.0
UNITS			UpH	µS/cm	mg/L	°C	m3/h
n			40	40	40	40	40
S _{sum} ²			0	0	0	0	0.619
CRITIC VALUE			0.009	18651	0.015	0.046	42.447
S _{sum} ² < CRITIC ??			ACCEPTABLE	ACCEPTABLE	ACCEPTABLE	ACCEPTABLE	ACCEPTABLE

Results of homogeneity and stability (2)

Use to calculate the σ_p

WASTE WATER ASSIGNED DEVIATION (TANK)				
PARAMETER	MEDIA	ASSIGNED DEVIATION	UNITS	METHOD
pH	7.30	0.20	UpH	EPA 9040B
CONDUCTIVITY	2545	331	$\mu\text{S/cm}$	ASTM D1125A
DISSOLVED OXYGEN	1.87	0.272	mg/L	HORWITZ MODIFIED BY THOMPSON
TEMPERATURE	24.7	0.50	$^{\circ}\text{C}$	USGS (COLLECTION OF WATER-QUALITY)
FLOW	75	15	m ³ /h	ISO 748:2007

RAW WATER ASSIGNED DEVIATION (RAW WATER CHANNEL)				
PARAMETER	MEDIA	ASSIGNED DEVIATION	UNITS	METHOD
pH	8.24	0.20	UpH	EPA 9040B
CONDUCTIVITY	832	108	$\mu\text{S/cm}$	ASTM D1125A
DISSOLVED OXYGEN	10.01	1.132	mg/L	HORWITZ MODIFIED BY THOMPSON
TEMPERATURE	20.9	0.50	$^{\circ}\text{C}$	USGS (COLLECTION OF WATER-QUALITY)

SEA WATER ASSIGNED DEVIATION (BEACH)				
PARAMETER	MEDIA	ASSIGNED DEVIATION	UNITS	METHOD
pH	8.34	0.20	UpH	EPA 9040B
CONDUCTIVITY	50960	6625	$\mu\text{S/cm}$	ASTM D1125A
DISSOLVED OXYGEN	8.69	1.004	mg/L	HORWITZ MODIFIED BY THOMPSON
TEMPERATURE	24.3	0.50	$^{\circ}\text{C}$	USGS (COLLECTION OF WATER-QUALITY)

HOMOGENEITY (by EURACHEM)

- 4 samples at random (time and space)
- Method with a repetibility less than $0.5 \sigma_p$
- Calculus of the total variance (S_{total})

$$S_{\text{TOTAL}} = \sqrt{s_{\text{time}}^2 + s_{\text{space}}^2 + s_{\text{analysis}}^2}$$

Homogeneous if $S_{\text{total}} < 0.3 p$

Results of homogeneity - Eurachem

TIEMPO	LUGAR 1 REP 1	LUGAR 1 REP 2	LUGAR 2 REP 1	LUGAR 2 REP 2	Tiempo 3 analisis 1	Tiempo 3 analisis 2							
1	24.64	24.66	24.60	24.70									
2	24.66	24.65	24.65	24.63									
3	24.65	24.64	24.66	24.71									
4	24.64	24.65	24.72	24.69									
5	24.70	24.70	24.75	24.72									
6	24.71	24.71	24.61	24.70									
7	24.70	24.71	24.86	24.69									
8	24.78	24.66	24.60	24.73									
9	24.63	24.69	24.71	24.71									
10	24.60	24.62	24.86	24.62									
Nº Lugares	2												
Frecuencias tiempo	10												
Nº Análisis	2												
	media Tiempo 1	media Tiempo 2	media Tiempo 3	desviación analisis entre tiempo1	desviación analisis entre tiempo 2	desviación analisis entre tiempo 3	desviación de las medias	medias	desviación medias al cuadrado	Desviaciones al cuadrado			
1	24.65	24.65	#iDIV/0!	0.0141	0.0707	#iDIV/0!	0.0000	24.65	0.0000	0.0002	0.0050	#iDIV/0!	
2	24.66	24.64	#iDIV/0!	0.0071	0.0141	#iDIV/0!	0.0106	24.65	0.0001	0.0001	0.0002	#iDIV/0!	
3	24.65	24.69	#iDIV/0!	0.0071	0.0354	#iDIV/0!	0.0283	24.67	0.0008	0.0000	0.0013	#iDIV/0!	
4	24.65	24.71	#iDIV/0!	0.0071	0.0212	#iDIV/0!	0.0424	24.68	0.0018	0.0000	0.0004	#iDIV/0!	
5	24.70	24.74	#iDIV/0!	0.0000	0.0212	#iDIV/0!	0.0247	24.72	0.0006	0.0000	0.0005	#iDIV/0!	
6	24.71	24.66	#iDIV/0!	0.0000	0.0636	#iDIV/0!	0.0389	24.68	0.0015	0.0000	0.0040	#iDIV/0!	
7	24.71	24.78	#iDIV/0!	0.0071	0.1202	#iDIV/0!	0.0495	24.74	0.0025	0.0001	0.0144	#iDIV/0!	
8	24.72	24.67	#iDIV/0!	0.0849	0.0919	#iDIV/0!	0.0389	24.69	0.0015	0.0072	0.0084	#iDIV/0!	
9	24.66	24.71	#iDIV/0!	0.0424	0.0000	#iDIV/0!	0.0354	24.69	0.0013	0.0018	0.0000	#iDIV/0!	
10	24.61	24.74	#iDIV/0!	0.0141	0.1697	#iDIV/0!	0.0919	24.68	0.0085	0.0002	0.0288	#iDIV/0!	
									0.0185	0.0096	0.0631	#iDIV/0!	0.0727
								SC muestras	0.33300			SC analisis	0.0727
								S medias	0.02855				
								S Tiempo	0.01630				
Media cuadratica Analisis:	0.00363												
Media cuadratica Tiempo:	0.01630												
Media cuadratica Lugar	0.01850												
Desviacion analisis	0.06029												
Desviación Lugar	0.01049												
Desviación Tiempo	0.07958												
Desviacion total:	0.10039												

Results of homogeneity - Eurachem


WASTE WATER				
PARAMETER	TOTAL S	ASSIGNED S	0.3*ASSIGNED S	COMPLIANCE
pH	0.057	0.20	0.060	OK
CONDUCTIVITY	18.097	331	99	OK
OXYGEN	0.081	0.272	0.082	OK
TEMPERATURE	0.100	0.50	0.150	OK
FLOW	3.348	15.21	4.563	OK

RAW WATER				
PARAMETER	TOTAL S	ASSIGNED S	0.3*ASSIGNED S	COMPLIANCE
pH	0.039	0.20	0.060	OK
CONDUCTIVITY	2.850	108	32.400	OK
OXYGEN	0.300	1.130	0.339	OK
TEMPERATURE	0.115	0.50	0.150	OK

SEA WATER				
PARAMETER	TOTAL S	ASSIGNED S	0.3*ASSIGNED S	COMPLIANCE
pH	0.051	0.20	0.060	OK
CONDUCTIVITY	96.820	6625	1987.500	OK
OXYGEN	0.297	1.004	0.301	OK
TEMPERATURE	0.140	0.50	0.150	OK

- Results must be collected at the end of the day after the PTS
- It would be accepted between one and three replicates (we will calculate the mean value)
- Outliers must be eliminated
- Calculus of the robust mean and robust standard deviation
- Calculus of the uncertainty $\left(\frac{\sigma_p}{\sqrt{n}} \right)$

- Target of the study
- Parameters of the PTS
- Main characteristics of the different locations
- Development of the PTS
- Information about homogeneity and stability (reference documents and values)
- Statistical treatment of the results



INFORME SOBRE EL EJERCICIO DE INTERCOMPARACION "IN SITU"



FECHA: 27 DE OCTUBRE DE 2010

LUGAR: CADIZ

ÍNDICE


1. OBJETO	3
2. PARÁMETROS DEL EJERCICIO	3
3. CARACTERÍSTICAS DE LOS PUNTOS DE MUESTREO	3
3.1. AGUA RESIDUAL	3
3.2. AGUA CONTINENTAL	4
3.3. AGUA MARINA	5
4. DESARROLLO DEL EJERCICIO.....	6
4.1. AGUA RESIDUAL	6
4.2. AGUA CONTINENTAL	6
4.3. AGUA MARINA	7
5. DATOS ADICIONALES	8
6. GENERALIDADES DE LA ORGANIZACIÓN DEL EJERCICIO.....	9
6.1. HOMOGENEIDAD Y ESTABILIDAD.....	9
6.2. TRATAMIENTO ESTADÍSTICO.....	10
6.2.1. Eliminación de resultados.....	10
6.2.2. Estimación del valor asignado.....	10
6.2.3 Estimación de la desviación standard asignada.....	10
6.2.4. Evaluación de la eficacia de los laboratorios (criterio Z).....	11
7. DESVIACIONES ASIGNADAS Y DATOS DE HOMOGENEIDAD	11
8. PRESENTACIÓN DE RESULTADOS.....	15

LAB	X ₁	X ₂	X ₃	MEDIA	SD	INTERVALO		Z-SCORE
1	3018	3017	3012	3016	3,21	3019	3012	-0,04
2	2970	2970	2940	2960	17,32	2977	2943	-0,19
3	3020	3010	3020	3017	5,77	3022	3011	-0,04
4	3093,9	3093,9	3093,9	3094	0,00	3094	3094	0,16
5	3051	3062	3064	3059	7,00	3066	3052	0,07
6	3058	3058	3057	3058	0,58	3058	3057	0,07
7	3020	3020	3020	3020	0,00	3020	3020	-0,03
8	3020	3020	3010	3017	5,77	3022	3011	-0,04
9	755	754	753	754	1,00	755	753	-5,93
10	3050	3050	3050	3050	0,00	3050	3050	0,05
11	3030	3004	3022	3019	13,32	3032	3005	-0,03

N
10

Valor consenso	3032
Desvest. asignada	384
Desvest. robusta	31
incertidumbre	10


conductivity in
waste water



LAB	X ₁	X ₂	X ₃	MEDIA	SD	INTERVALO		Z-SCORE
1	7,9	8,0	8,0	7,97	0,06	8,02	7,91	0,10
2	7,87	7,93	7,85	7,88	0,04	7,92	7,84	0,01
3	7,87	7,92	7,85	7,88	0,04	7,92	7,84	0,01
4	8,32	8,31	8,27	8,30	0,03	8,33	8,27	0,46
5	-	-	-					
6	7,78	7,80	7,78	7,79	0,01	7,80	7,78	-0,10
7	7,88	7,71	7,82	7,80	0,09	7,89	7,72	-0,08
8	7,78	7,82	7,80	7,80	0,02	7,82	7,78	-0,08
9	8,43	8,41	8,43	8,42	0,01	8,43	8,41	0,60
10	7,53	7,53	7,50	7,52	0,02	7,54	7,50	-0,39
11	-	-	-					

N
8

Valor consenso	7,87
Desvest. asignada	0,92
Desvest. robusta	0,14
incertidumbre	0,05




dissolved oxygen in raw water

FINAL REPORT

LAB	X ₁	X ₂	X ₃	MEDIA	SD	INTERVALO		Z-SCORE
1	8,3	8,3	8,3	8,30	0,00	8,30	8,30	-0,27
2	8,18	8,21	8,18	8,19	0,02	8,21	8,17	-0,82
3	8,35	8,33	8,33	8,34	0,01	8,35	8,33	-0,09
4	-	-	-					
5	-	-	-					
6	8,40	8,41	8,41	8,41	0,01	8,41	8,40	0,26
7	8,36	8,36	8,35	8,36	0,01	8,36	8,35	0,01
8	8,38	8,40	8,35	8,38	0,03	8,40	8,35	0,11
9	8,35	8,35	8,35	8,35	0,00	8,35	8,35	-0,02
10	8,39	8,39	8,42	8,40	0,02	8,42	8,38	0,23
11	-	-	-					

N
8

Valor consenso	8,35
Desvest. asignada	0,20
Desvest. robusta	0,05
incertidumbre	0,02



pH in sea water

- PTS: 6 in two years (3 in 2010 and 3 in 2011)
- Participants: nearly 35 per year
- During two years, we have done 3 in 2010 and 3 in 2011 (two of them will be this month)
- Since 2010, this PTS has been accredited by ENAC



**THANK YOU VERY MUCH
FOR YOUR ATTENTION**

